

DELHI DEVELOPMENT AUTHORITY

NO:EM1(10)83/68


Dated: 12.1.93

C I R C U L A R NO: 377

SUBJECT : PROVISION OF SHORT PIPE NIPPLES OF THE SAME  
GRADE/SPECIFICATIONS AS PRESCRIBED FOR G.I. PIPES.  
\*\*\*\*\*

During inspection of one of the works in DDA, CTE had observed that short pipe nipple provided to G.I. lines were not Galvanised and appeared to be made out of light quality pipes, though these were measured as medium pipe lengths.

It is enjoined upon all field staff to ensure that short pipe nipples provided in the GI pipe lines should invariably be of Galvanised Iron of the same grade as that of the GI pipe line. In all future works, the NIT approving authorities should incorporate this as a special condition in the NIT to avoid any contractual implications.



( H.D. SHARMA )  
ENGINEER MEMBER

All Area Engineers

All Suptd. Engineers


All Executive Engineers

Director(Hort.) North & South

G.M., I.S.H.T.

Concerned file No.EM8(97)88/CTE/WZ

Copy to:- Vice-Chairman, DDA, for information.



( S.M. MADAN )  
DIRECTOR(MONITORING)