

DELHI DEVELOPMENT AUTHORITY
(EM'S OFFICE)

NO: EM.1(10)77/ Vol-I/3925

Dated: 28.2.95

INSTRUCTION NO 452

SUB: USE OF PROPER M.S. COVERS AND FRAMES FOR
OVERHEAD RCC TANKS IN ORDER TO MAKE IT
MOSQUITO PROOF.

CTE's Organisation, during one of the inspections of DDA work, had observed that the M.S. Frames and Covers used in RCC Tanks were not of proper shape as specified in clause 19.2.17 of CPWD Specifications Volume-II, which is essential to make the tanks mosquito proof.

It is, therefore, enjoined upon all field engineers to ensure that in all future works M.S. Covers and Frames of proper shape, as mentioned in figure 90 of CPWD Specification Volume-II, only are used in the overhead RCC tanks.

[Signature]
(R.L. HANS)
ENGINEER MEMBER

COPY TO:-

1. All CEs i/c QC, Elect. & Design.
2. All SEs i/c. QC, Elect. and Design.
3. All EEs i/c. QC, Elect., & Design.
4. File No. EM.8(94)EE/CTE/WZ.

[Signature]
ENGINEER MEMBER

D.D.H.

office of (E/WZ)

NO (E/WZ) 12(9)95/776

dt 7/3/95

Copies to all SE's, SE(DLF), EEs, TO, & EAs for
information & necessary action please.

[Signature]
To to (E/WZ)

SK

E/E

Again under Appendix 48 to para 32.5.4 of CPWD Manual Vol.II, the item at Sl.No.4 for which secured advance can be granted under Category 'A' for civil work is :-

"Finished products of brass, iron or steel such as doors and window frames, wire mesh gate, G.I sheets etc."

Thus secured advance can only be given for finished products of metal/metal alloy door and window frames.

It is, therefore, enjoined upon all concerned to ensure that secured advance is paid for materials actually brought by the contractor in conformity with the manual/codal provisions.


(R.L. HANS)
ENGINEER MEMBER

COPY TO:-

1. All CEs including CE(QC) & CE(Design).
2. All SEs including SE(QC), DCA.
3. All EEs.
4. File No. EM.8(25)91/CIE/WZ/LEW.

:R.K.: