

DELHI DEVELOPMENT AUTHORITY

No. EM1(10)95/17457

Dated: 28.9.95

CIRCULAR NO. 469

Sub: Use of I.S.I marked primers for steel work.

.....

C.T.F., during one of their inspections of a DDA work, had observed that zinc chromate primer used on C.I pipes and steel work was not from the approved manufacturers.

In this context, attention is drawn to the provisions of para 13.34.1.2 of CPWD Specifications 1977, Vol.I read with correction slip No.44 issued by CPWD vide ref. No.CDO/SS/CS/Vol.I/19 dated 1.9.88 which stipulates that red oxide zinc chromate primer conforming to IS 2074-1979 is required to be used for steel work.

It is further pointed out that presently a good number of ISI marked steel primers conforming to the above specifications are readily available in the market.

It is, therefore, enjoined upon all the field engineers to, henceforth, ensure that only IS marked steel primers conforming to the above mentioned CPWD/ISI Specifications are used in all the works of DDA.

In this context, attention is drawn to the provisions of para 13.34.1.2 of CPWD Specifications

(Signature)
28.9.95
(R.L. HANS)
ENGINEER MEMBER

1. All Chief Engineers i/c C.F.(QC)
2. All Superintending Engineers i/c SE(QC).
3. All Ex. Engineers (Civil) /Dy. Director (Hort.)
4. File No. EM14(23)95/Vig./Pt./DDA.

office of CE(w2)

No CE(w2) 12(9)95/vols/3451 dt 6/10/95

Copy to all SE's, SE(P) & FO

For info. in a pl.

SK

To to CE(w2)