

DELHI DEVELOPMENT AUTHORITY.

NO: Sm 1 (10) 83/369

DATE: 8-1-88

CIRCULAR NO. 221

It is necessary that water supplied from the tubewells in DDA colonies is treated for all the qualities necessary for drinking water. Sometimes the water from the tubewells is directly pumped into quarters and sometimes the water is collected in under-ground tank and then pumped to the various units. In any particular system, it is necessary that the water, before it is supplied, remains in contact with adequate chlorine for atleast $\frac{1}{2}$ an hour. Therefore, the time of application and the quantity of chlorine content should regulated to achieve this $\frac{1}{2}$ an hour contact at the beginning and also residual chlorine content at the end within the permissible limits. All the Suptdg. Engineers, are requested to kindly instruct the various officers to ensured the two above aspects systematically and regularly.

Sd/-

(V.S.MURTI)
ENGINEER MEMBER.

Copy to All Chief Engineers/Suptdg. Engineers.

P.K. J...
8/1/88
B.O.I to E.M.
DDA.