

**DELHI DEVELOPMENT AUTHORITY
OFFICE OF THE EXECUTIVE ENGINEER (E)
ELECTRICAL DIVISION 13
NEAR HASANPUR DTC BUS DEPOT DELHI-110092**

CORRIGENDUM No. 1

Name of Work: M/o completed scheme under NA- II (Hort. Zone).
SH:-Supplying, Installation and Replacement of Clear water borewell submersible pump sets and veda type sewage pump sets in various parks under HD-1,4&6/DDA.
NIT No. 03/EE/ELD-13/DDA/2024-25
Estimated Cost:-Rs.24,18,033/-

The following Term and Condition is being added and shall be treated as part of NIT No. 03/EE/ELD-13/DDA/2024-25.


Sr.No.(15.00)Additionally:- Old/unused material will be dismantle by Agency as per directions of Engineer-in-charge and dismantle unused/unserviceable material shall belong to agency. Rebate on old materials have already been taken in the estimate.

Sr. No.	Item No.	Existing	May be read as
1.	3.00 of BOQ	Supplying of open well submersible pump set with CI impeller & CI body of highly, efficient, wear resistant alongwith submersible squirrel cage induction motor for operation on 3 Phase,415 volts, 50 HZ,AC supply, oil filled alongwith mechanical seal including holding clamp made out of MS plate of size 10 mm x80mm of suitable length in the existing water tank etc. as required suitable for following duties. (a) Discharge-30-63 LPM (b) Head- 9-19 mtr (c)liquid – sewage water (d) capacity-5.5 HP/4.10 KW	Supplying, replacement, testing, commissioning of open well submersible pump set with CI impeller & CI body of highly efficient, wear resistant alongwith submersible squirrel cage induction motor for operation on single phase 240 volts, 50 HZ AC supply, oil filled alongwith mechanical seal i/c holding clamp made out of MS plate of size 10mm x80mm of suitable length in the existing water tank etc. as reqd. suitable for following duties. (a) Discharge-400-100LPM (b) Head- 2-11 mtr (c)liquid – sewage water (d) capacity- 1HP/0.75 KW

Due to Corrigendum No.1 in above mentioned NIT the date & time are extended as below:

	Existing Date	Due Date
Bid Submission End Date	17.05.2024 upto 3:00 P.M	21.05.2024 Upto 3:00 P.M.
Bid Opening Date	18.05.2024 upto 3:30 PM	22.05.2024 Upto 3:30 PM

Other 1 to 14 Nos. terms & conditions and details of NIT remain the same. This corrigendum shall be the part of NIT.


16/05/24
EXECUTIVEENGINEER (E)
ELECTRICAL DIVISION-13

Dated: 16/05/24

No. F97(03)/ED-13/A/C/DDA/24-25/178

Copy to:-

1. SE(HCC-1)//DDA for kind information.
2. The E.E.(E)/QAC/DDA
3. Sr.A.O.(CAU)/ Horticulture/DDA
4. EE/ELD-1,2,3,4,5,6,7,8,9,10,11,12/DDA
5. All AE's/Electrical Division No. 13/DDA
6. AE(P)/ELD-13/DDA
7. The electrical engineers Contractor Association, 2362/1. Maharaja Complex, Mina Road, Patel Nagar, New Delhi.
8. Notice Board, Electrical Division No. 13/DDA
9. Dy. Director (System), DDA, Vikas Sadan, New Delhi
10. AAO/ELD-13,
11. Head Clerk/ELD-13/DDA
12. M/s eprocure.gov.in/eprocure/app.or www.dda.org.in CGO Complex, Lodhi Road, New Delhi. For any assistance on
13. e-tendering please contact concerned office or NIC on e-mail: [cphp-nic@nic.in](mailto:cppp-nic@nic.in) or 24X7 helpline number 1800-233-7315
14. E-mail: ddatender@dda.org.in

EXECUTIVEENGINEER(E)
ELECTRICAL DIVISION-13